### **Product data sheet**


## Power connectors




Product description M25 male panel mount connector, Contacts: 3, shielding is not possible, solder, IP40

Area **M25 series 691** Order number **09 0035 00 03** 

# Illustration





# Technical data

### **General values**

Connector design Connector locking system Termination Wire gauge (mm) Wire gauge (AWG) Upper limit temperature Lower limit temperature Customs tariff number Packaging Unit male panel mount connector screw solder 1.50 mm<sup>2</sup> 16 85 °C - 40 °C 85369010

### **Electrical values**

Rated current (40 °C) 10 A Rated voltage 250 V Rated impulse voltage 2500 V Pollution degree Overvoltage category Ш Insulating material group Ш  $\geq 10^{10} \, \Omega$ Insulation resistance shielding is not possible EMC compliance Degree of protection IP40 Mechanical operation > 50 Mating cycles

### **Material**

Contact material CuZn (brass)
Contact plating Ag (silver)
Contact body material PBT (UL94 V-0)
Housing material GD-AL eloxiert

### **Product data sheet**

### Power connectors



Product description M25 male panel mount connector, Contacts: 3, shielding is not possible, solder, IP40

Area **M25 series 691** Order number **09 0035 00 03** 

### Security notices

The connector must not be connected or separated under load. Non-observance and incorrect use can result in personal injury.

The connectors are designed for use in plant, control system and electrical equipment. The end user is responsible for checking whether the connectors are suitable for use in other applications.

To prevent the connector being opened unintentionally when used in electrical circuits containing hazardous life parts, the thread between the housing and the connector head must be secured using a suitable cyanoacrylate adhesive. This does not apply to connectors used in SELV and PELV circuits according to IEC 61140 (EN 61140, VDE 0140-1)

Connectors used in electrical circuits containing hazardous life parts must only be assembled and used by or under the supervision of persons with the requisite electrotechnical training, taking the applicable regulations and standards into account.