



Main

Relay application	Generator
Range of product	Sepam series 80 NPP Sepam series 80
Device short name	G87
Control and monitoring type	Circuit breaker/contactors control ANSI code: 94/69 (option) Latching/acknowledgement ANSI code: 86 Logic discrimination ANSI code: 68 (option) Switching of groups of settings Annunciation ANSI code: 30 Automatic transfer (AT) (option) Logipam programming (ladder language) (option) Logic equation editor 200 operators
Metering type	Positive sequence voltage Vd/rotation direction Frequency Calculated active and reactive energy (+/- W.h, +/- VAR.h) Active and reactive energy by pulse counting (+/- W.h, +/- VAR.h) (option) Phase current I1, I2, I3 RMS Demand current I1, I2, I3 Peak demand current IM1, IM2, IM3 Measured residual current I'0 Voltage U21, U32, U13, V1, V2, V3 Residual voltage V0 Negative sequence voltage Vi Active power P, P1, P2, P3 Reactive power Q, Q1, Q2, Q3 Apparent power S, S1, S2, S3 Peak demand power PM, QM Power factor Temperature (16 RTDs) (option) Phase current I'1, I'2, I'3 RMS Rotation speed (option) Neutral point voltage Vnt Measured residual current I0, calculated I'0Σ Calculated residual current I'0Σ
Network and machine diagnosis type	Unbalance ratio/negative sequence current Ii Disturbance recording Thermal capacity used Remaining operating time before overload tripping Waiting time after overload tripping Running hours counter/operating time Tripping context Phase fault and earth fault trip counters Harmonic distortion (THD), current and voltage Ithd, Uthd

Disclaimer: This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications

	Difference in amplitude, frequency and phase of voltages with synchro-check option Apparent positive sequence impedance Z_d Apparent phase-to-phase impedances Z_{21} , Z_{32} , Z_{13} Differential current I_{diff1} , I_{diff2} , I_{diff3} Through current I_{t1} , I_{t2} , I_{t3} Third harmonic voltage, neutral point residual Current phase displacement θ Phase displacement Datalog (DLG)
Switchgear diagnosis type	Cumulative breaking current CT/VT supervision ANSI code: 60FL Trip circuit supervision ANSI code: 74 (option) Auxiliary power supply monitoring Nb of operations, operating time, charging time, nb of racking out operations (option)

Complementary

Type of measurement	Power factor Voltage Power (P,Q) Energy Peak demand power Rotation speed Current Frequency Harmonic distortion (I THD & U THD) Temperature
Protection type	Neutral voltage displacement ANSI code: 59N Breaker failure ANSI code: 50BF Directional earth fault ANSI code: 67N/67NC Directional phase overcurrent ANSI code: 67 Synchro-check ANSI code: 25 (option) Overvoltage (L-L or L-N) ANSI code: 59 Temperature monitoring (16 RTDs) ANSI code: 38/49T (option) Thermal overload for machines ANSI code: 49RMS Overfluxing (V/Hz) ANSI code: 24 Field loss (underimpedance) ANSI code: 40 Pole slip ANSI code: 78PS Overspeed (2 set points) ANSI code: 12 (option) Underspeed (2 set points) ANSI code: 14 (option) Directional reactive overpower ANSI code: 32Q Machine differential ANSI code: 87M Underimpedance ANSI code: 21B Inadvertent energisation ANSI code: 50/27 Third harmonic undervoltage/100 % stator earth fault ANSI code: 27TN/64G2 Third harmonic undervoltage/100 % stator earth fault ANSI code: 64G Negative sequence/unbalance ANSI code: 46 Overfrequency ANSI code: 81H Underfrequency ANSI code: 81L Positive sequence undercurrent ANSI code: 27D Remanent undervoltage ANSI code: 27R Undervoltage (L-L or L-N) ANSI code: 27 Negative sequence overvoltage ANSI code: 47 Phase overcurrent ANSI code: 50/51 Earth fault/sensitive earth fault ANSI code: 50N/51N Earth fault/sensitive earth fault ANSI code: 50G/51G Directional active overpower ANSI code: 32P Voltage-restrained overcurrent ANSI code: 50V/51V
Communication port protocol	Measurement readout (option) : Modbus Remote indication and time tagging of events (option) : Modbus Remote control orders (option) : Modbus Remote protection setting (option) : Modbus Transfer of disturbance recording data (option) : Modbus
Input output max capacity	42 inputs + 23 outputs
Communication compatibility	DNP3 Modbus RTU Modbus TCP/IP IEC 61850 gose message IEC 60870-5-103 IEC 61850
User machine interface type	Remote Advanced Without

Mimic-based

Packing Units

Package 1 Weight	0.001 kg
Package 1 Height	0.010 dm
Package 1 width	0.010 dm
Package 1 Length	0.020 dm

Offer Sustainability

EU RoHS Directive	Not applicable, out of EU RoHS legal scope
-------------------	--
